



Energy Efficient Building

Tan Chin Hong

Green Building Consultant, IEN Consultants
Energy Efficiency and Green Building Consultancy

www.ien.com.my
Malaysia | China

We are a Green Building Consultancy

- ❖ 15 year track record in Malaysia with European roots
- ❖ Portfolio of 3.2 million square meters of green building space

- ❖ Building consultancy services:
 - a) Energy efficiency consultancy
 - b) Daylighting design consultancy
 - c) Green building certification (GBI, LEED, BREEAM, Green Mark)
 - d) Masterplanning



A real conversation that I had here in Malaysia.....




Courtesy of Gregers Reimann/IEN Consultants Sdn Bhd / Illustration by Rachel Chen Ruiqi

The Star newspaper, 16 August 2013


I optimised the design of buildings through computer simulation - and then they are built without any big surprises ☺

ENERGY EFFICIENCY

Denmark's experience




GET A HAT




ENERGY EFFICIENCY

Denmark's experience





ENERGY EFFICIENCY

Denmark's experience



ENERGY EFFICIENCY

Three Fundamental Observations



PWD/BSEEP in collaboration with the United Nations Development Program (UNDP) has been promoting energy efficiency in buildings in support of the United Nations Sustainable Development Goals (SDG).


17 goals to Transform the World




***Funding for SDG Programmes and Projects:
Through the existing development mechanisms
(5-year Malaysia Plans)***

ELEVENTH MALAYSIA PLAN 2016-2020

ANCHORING GROWTH ON PEOPLE




Priority SDGs




Funds are channelled through the programmes and projects under the 11MP strategic thrusts that fit the SDG goals

MALAYSIA: Energy Efficiency has a good Economic Internal Rate of Return

(Input to 9th Malaysian Plan by Danida, 2005)



Cheapest Way to reduce carbon footprint.



What is Energy Efficient Building

Introduction of BEI (Building Energy Intensity)

$$BEI = ((TBEC - CPEC - DCEC) / (GFA(\text{excluding carpark}) - DCA - GLA * FVR)) * (52 / WHO)$$

Green Building Index

Introduction of EUI (Energy Usage Index)

$$EUI = ((TBEC - DCEC) / (GFA(\text{excluding carpark}) - DCA - GLA * FVR)) * (52 / WHO)$$

Green Mark

Simplest way to calculate EUI is by use TNB bill total KWH, and divide by Building GFA.



SALINAN			
Tarikh Bil : 02.11.2017			
Bil : LPC			
Tunggakan	RM	Amaun	<u>Bayar Sebelum</u>
Caj Semasa	RM	473,060.60	Segera
Penggenapan	RM	11,339.88	02.12.2017
Jumlah Bil	RM	0.02	
Bil Terdahulu	RM	484,400.50	
		0.00	Bayaran Akhir
			RM
			636.00
Jenis Bacaan	: Bacaan Sebenar		
Tempoh Bil	: 13.01.2017 - 31.01.2017 (19 Hari)		
Tarif	: C1:Perdagangan		
Blok Tarif (kWh/kW)	Kegunaan (kWh/kW)		
Kehendak Maksima	21,666.00		
	154.00		
	Kadar(RM)	Amaun(RM)	
	0.3650	7,908.09	
	30.3000	2,955.26	

Untuk maklumat bil dan
bayaran terdahulu, sila
layari-
<http://www.mytnb.com.my>
atau hubungi Hotline TNB
1 300 88 5454

Untuk gangguan bekalan
atau kerosakan lampu jalan
TNB sila hubungi melalui
telefon/SMS: 15454

Untuk pertanyaan, sila
hubungi:
**TNB KUALA LUMPUR -
PUSAT**

Energy Efficient Building Benchmarking


Reference:

https://www.bca.gov.sg/GreenMark/others/BCA_BEBR_Abridged_FA_2016.pdf

Energy Use Intensity (EUI) of Office Buildings

Large Office Buildings (GFA $\geq 15,000 \text{ m}^2$)


Chart 12: EUI of 157 Large Office Buildings



Energy Use Intensity (EUI) of Office Buildings

Small Office Buildings (GFA <15,000 m²)


Chart 13: EUI of 243 Small Office Buildings



Energy Use Intensity (EUI) of Hotels

Large Hotels (GFA $\geq 7,000 \text{ m}^2$)


Chart 14: EUI of 75 Large Hotels



Energy Use Intensity (EUI) of Hotels

Small Hotels (GFA <7,000 m²)

Chart 15: EUI of 210 Small Hotels




Energy Use Intensity (EUI) of Retail

Buildings

Large Retail Buildings (GFA $\geq 15,000 \text{ m}^2$)

Chart 16: EUI of 79 Large Retail Buildings




Energy Use Intensity (EUI) of Retail




Small Retail Buildings (GFA < 15,000m²)

Chart 17: EUI of 93 Small Retail Buildings



Energy Use Intensity (EUI) of Mix Developments

Chart 18: EUI of 64 Mixed Developments



Energy Efficient Buildings in South-East Asia






CHART 1.1 | TYPICAL ENERGY BREAKDOWN IN A BUILDING



Building Energy Analysis with Computer Simulation







Energy Efficient Building Strategies

Energy Optimisation

Simulation steps and improvements





PASSIVE DESIGN

OTTV = Overall Thermal Transfer Value

OTTV is a measure of the average heat gain into a building through the building envelope.

MS 1525:2007 requirement :
 $OTTV \leq 50 \text{ W/m}^2$

OTTV CONCEPT

OTTV CALCULATION:

$$15a(1 - WWR)U_w + 6(WWR)U_f + 194xCFxWWRxSC$$

0.2%-5%

6(WWR)U_f

194xCFxWWRxSC

Heat Conduction through Walls

Heat Conduction Through Windows

Solar Heat Gain through Windows

≤ 50 W/m²

α = solar absorptivity of the opaque wall


WWR = Window to wall ratio

U_w = Thermal Transmittance of opaque wall W/m^2K

U_f = Thermal Transmittance of fenestration system W/m^2K

CF = Solar Correction factor

SC = Shading coefficient of the fenestration system



Correction Factor : (MS1525:2007)

Orientation	CF
North	0.9
Northeast	1.09
East	1.23
Southeast	1.13
South	0.92
Southwest	0.9
West	0.94
Northwest	0.9


Shading Coefficient (SC)

$$SC = SC1 \times SC2$$

SC 1 = Glass Shading Coefficient

SC 2 = External Shading Coefficient

External Shading Coefficient



$$R1 = \frac{P}{H}$$

SC2 Refer to Table 5 MS1525:2007

Strategy Reducing OTTV

Make sure the most determining variables is low enough:

All Variables are below:

1. CF
2. WWR
3. Uw
4. Uf
5. SC

Summary:

- Minimize WWR, especially at East ,NorthEast, SouthEast
- Minimize SC
 - SC of Glass
 - SC of sunshade

Example of East Façade OTTV

Base Case

Window: 50% of total façade

Window: Single Glaze Tinted

Opaque Façade: Opaque façade is made from brickwall + plaster

α Value: 0.8

WWR	Uw	Uf	CF	SC
0.5	2.44	5.7	1.23	0.7



$15 \times \alpha \times (1 - \text{WWR}) \times \text{UW}$	$6 \times (\text{WWR}) \times \text{Uf}$	$194 \times (\text{WWR}) \times \text{SC} \times \text{CF}$	OTTV
14.64	17.1	83.52	115.26

	WWR	Uw	Uf	CF	SC	OTTV	OTTV Reduction
Base	0.5	2.44	5.7	1.23	0.7	115.26	
Step 1	0.4	2.44	5.7	1.23	0.7	98.06	15%
Step 2	0.4	0.55	5.7	1.23	0.7	84.45	14%
Step 3	0.4	0.55	5.7	1.23	0.539	69.09	18%
Step 4	0.4	0.55	1.6	1.23	0.27	33.52	51%

Efficient Lighting Design Strategies



COMMON MISCONCEPTION - SUNLIGHT IS “HOTTER” THAN ELECTRIC LIGHTS



Daylighting Harvesting

- ▶ Daylight through normal glazing is **2.6 times cooler** than people think
- ▶ Daylight through high performance glazing is **4.9 times cooler** than people think

Solar Light interacting with Glazing







Figure 4.15: Misconception of lumen efficacy of daylight. If fluorescent light is assumed to have a lumen efficacy of 90 lm/W then the lumen efficacy of daylight was set to 47 lm/W, while in reality it is 160% higher at 122 lm/W (outdoors) or almost 400% higher at 229 lm/W when coming through a spectrally selective window.

ORIENTATION MATTERS



Sunpath diagram for Malaysia



North & South windows can easily be shaded from direct sun by horizontal overhangs

Lighting Power Density of MS 1525

Type of Usage	Max. lighting power W/m ²
Restaurants	15
Offices	15
Classrooms/ Lecture Theatres	15
Auditoriums/ Concert Halls	15
Hotel/ Motel Guest Rooms	15
Lobbies/ Atriums/ Concourse	20
Supermarkets/ Department Stores/ Shops	25
Stores/ Warehouses/ Stairs/ Corridors/ Lavatories	10
Car Parks	5

Recommended Lux Value in MS 1525

Task	Illuminance (Lux)	Example of Applications
Lighting for infrequently used area	20	Minimum service illuminance
	100	Interior walkway and car-park
	100	Hotel bedroom
	100	Lift interior
	100	Corridor, passageways, stairs
	150	Escalator, travellator
	100	Entrance and exit
	100	Staff changing room, locker and cleaner room, cloak room, lavatories, stores.
	100	Entrance hall, lobbies, waiting room
	300	Inquiry desk
	200	Gate house
Lighting for working interiors	200	Infrequent reading and writing
	300 – 400	General offices, shops and stores, reading and writing
	300 – 400	Drawing office
	150	Restroom
	200	Restaurant, Canteen, Cafeteria
	150 – 300	Kitchen
	150	Lounge
	150	Bathroom
	100	Toilet
	100	Bedroom
	300 – 500	Class room, Library
	200 – 750	Shop / Supermarket/Department store
	300	Museum and gallery
Localised lighting for exacting task	500	Proof reading
	1000	Exacting drawing
	2000	Detailed and precise work



Case study



GEO Building
(Malaysia. formerly ZEO Building, 2007)
Daylighting case study

Good Orientation for Daylighting

Solar chart for Kuala Lumpur (3.15° North)




SUCCESS STORIES - GREEN ENERGY OFFICE (GEO) BUILDING, BANGI




daylight window with built-in micro-louvres

view-out windows with manual roller blinds

cubicles with transparent partitions




Split Window Design



Daylight Responsive Lighting


Daylight Measurements



- Lighting consumption: 0.56 W/m²
- Code requirement: 15 W/m²


25 times more efficient

Daylight Responsive Lighting



GEO Building Daylight Measurements

Light levels (lux) measured in GEO Building, 9 April 2012, 4:30 pm on rainy and gloomy afternoon. None of the general lighting had been switched on by the staff



Air Distribution System

KKR2_GFX - Graphic1 KKR2_EMS_GFX - Wb Px Vi... 192.168.1.2:90/ord?file:*px_BAS/KKR2_EMS/ENERGY/EMS_ENERGY_SUMMARY.pv

Actions View Audio/Video File transfer Extras

Files px_BAS KKR2_EMS ENERGY EMS_ENERGY_SUMMARY.px

Home Back ENERGY SUMMARY OFFICE ENERGY USAGE (LOW ZONE) OFFICE ENERGY USAGE (HIGH ZONE) MAX DEMAND BEI TRENDING PARAMETERS CHART

ENERGY SUMMARY

Annual Summary

Renewable Energy	Energy Efficiency	Total Energy
Energy Saved (KWH/Year)	96.94 MW-hr	6303.36 MW-hr
Money Saved (RM/Year)	35384.37	2300724.69
CO2 Saved (Tons/Year)	775.55	50426.84
		6400.30 MW-hr
		2336109.06
		51202.39

BET's Comparison with Typical Building

KKR2 Building	Versus	Typical Building
98.2 kWh/m2/year		220.0 kWh/m2/year

Current Performance

Building Electrical Usage (kW)	1600.00 kW
Building Indoor Temperature (Degree C)	22.5 °C
Building Outdoor Temperature (Degree C)	27.9 °C
Building Average CO2 Level (ppm)	637.7 ppm
Building Cooling Usage (kWc)	3110.7
System COP	4.9

Total Energy Usage Based on Categories

	Current Active Power (kW)	Last Month Usage (kWh)
Chiller Plant	630.00 kW	
ACMV System- AHUS&FANS	261.01 kW	
LIGHTING SYSTEM	201.61 kW	
SMALL POWER System	96.47 kW	
DATA CENTRE	35.16 kW	35.16 kW
LIFT	86.79 kW	86.79 kW
CARPARK(Lighting,Power & Ventilation)	100.31 kW	100.31 kW
SOLAR PV(Energy Generated)	24.59 kW	24.59 kW
OTHER SERVICE	188.7 kW	188.7 kW
TOTAL ENERGY USAGE	1600.00 kW	1600.00 kW

Maximum Demand

Incoming 1 Maximum Demand Within Past 30 days (kW)	751.6
Incoming 1 Date and Time of Maximum Demand	09-Sep-15 8:50 AM SGT
Incoming 2 Maximum Demand Within Past 30 days (kW)	1156.7
Incoming 2 Date and Time of Maximum Demand	07-Sep-15 8:09 AM SGT

Water Consumption

INCOMING - SYABAS	59294.0 m ³
FIRE TANK -(P1A+L18+L36)	430041.9 m ³
CAFE (P8)	275.9 m ³
DCW-BASIN (L18 & L36)	12282.0 m ³
DCW-WC&URINAL (L18&L36)	9014.4 m ³
DCW-INTERMEDIATE	13290.3 m ³
COOLING TOWER	2156705.4 m ³
WATER LEAK	
BACKUP	
TREATED WASTE WATER TANK	397.4 m ³
RAIN WATER TANK	42.0 m ³
RAIN WATER USED	41.3 m³

KKR2 Internet access Network Internet access

Alarm Portal



File Edit View History Bookmarks Tools Help

KKR2_GFX - Wb Px View

KKR2_EMS_GFX - Wb Px

Actions

View

Audio/Video

File transfer

Extras

Remote update

192.168.1.2:90/ord?file:^px_BAS/KKR2_EMS/ENERGY/EMS_ENERGY_SUMMARY.px

Search

Files px_BAS KKR2_EMS ENERGY EMS_ENERGY_SUMMARY.px

ENERGY SUMMARY

Annual Summary

Renewable Energy	Energy Efficiency	Total Energy
Energy Saved (KWH/Year)	97.18 MW·hr	14665.51 MW·hr
Money Saved (RM/Year)	35470.23	5352910.11
CO2 Saved (Tons/Year)	777.43	117324.06
		118101.49

Current Performance

Building Electrical Usage (kW)	1505.00 kW
Building Indoor Temperature (Degree C)	22.1 °C
Building Outdoor Temperature (Degree C)	26.3 °C
Building Average CO2 Level (ppm)	690.5 ppm
Building Cooling Usage (kWc)	2888.4
System COP	4.5

Maximum Demand

Incoming 1 Maximum Demand Within Past 30 days (kW)	751.6
Incoming 1 Date and Time of Maximum Demand	09-Sep-15 8:50 AM SGT
Incoming 2 Maximum Demand Within Past 30 days (kW)	1165.8
Incoming 2 Date and Time of Maximum Demand	14-Sep-15 8:01 AM SGT

BEI's Comparison with Typical Building

KKR2 Building	Versus	Typical Building
-63.4 kWh/m ² /year		220.0 kWh/m ² /year

Total Energy Usage Based on Categories

	Current Active Power (kW)	Last Month Usage (kWh)
Chiller Plant	640.00 kW	100,000.00
ACMV System- AHUs&FANS	73.75 kW	
LIGHTING SYSTEM	167.65 kW	
SMALL POWER System	70.84 kW	
DATA CENTRE	0.00 kW	44,414.60
LIFT	20.76 kW	16,983
CARPARK(Lighting,Power & Ventilation)	106.78 kW	60,358.80
SOLAR PV(Energy Generated)	3.28 kW	7,914.30
OTHER SERVICE	425.2 kW	
TOTAL ENERGY USAGE	1505.00 kW	

Water Consumption

	Today Usage (m ³)	Last Month Usage (m ³)
INCOMING - SYABAS	64694.5 m ³	
FIRE TANK -(P1A+L18+L36)	429898.7 m ³	
CAFE (P8)	237.5 m ³	
DCW-BASIN (L18 & L36)	22869.7 m ³	
DCW-WC&URINAL (L18&L36)	39462.8 m ³	
DCW-INTERMEDIATE	0.0 m ³	
COOLING TOWER	0.0 m ³	
TREATED WASTE WATER TANK	658.4 m ³	
RAIN WATER TANK	42.0 m ³	
RAIN WATER USED	60.2 m ³	

Air Distribution System

► MS 1525 Motor Efficiency

Table 15. Class definition for 4-pole motors

Motor Capacity (kW)	Motor Efficiency (%)	
	Motor Class Eff2	Motor Class Eff1
1.1	≥ 76.2	≥ 83.8
1.5	≥ 78.5	≥ 85.0
2.2	≥ 81.0	≥ 86.4
3	≥ 82.6	≥ 87.4
4	≥ 84.2	≥ 88.3
5.5	≥ 85.7	≥ 89.2
7.5	≥ 87.0	≥ 90.1
11	≥ 88.4	≥ 91.0
15	≥ 89.4	≥ 91.8
18.5	≥ 90.0	≥ 92.2
22	≥ 90.5	≥ 92.6
30	≥ 91.4	≥ 93.2
37	≥ 92.0	≥ 93.6
45	≥ 92.5	≥ 93.9
55	≥ 93.0	≥ 94.2
75	≥ 93.6	≥ 94.7
90	≥ 93.9	≥ 95.0

Table 16. Class definition for 2-pole motors

Motor Capacity (kW)	Motor Efficiency (%)	
	Motor Class Eff2	Motor Class Eff1
1.1	≥ 76.2	≥ 82.8
1.5	≥ 78.5	≥ 84.1
2.2	≥ 81.0	≥ 85.6
3	≥ 82.6	≥ 86.7
4	≥ 84.2	≥ 87.6
5.5	≥ 85.7	≥ 88.6
7.5	≥ 87.0	≥ 89.5
11	≥ 88.4	≥ 90.5
15	≥ 89.4	≥ 91.3
18.5	≥ 90.0	≥ 91.8
22	≥ 90.5	≥ 92.2
30	≥ 91.4	≥ 92.9
37	≥ 92.0	≥ 93.3
45	≥ 92.5	≥ 93.7
55	≥ 93.0	≥ 94.0
75	≥ 93.6	≥ 94.6
90	≥ 93.9	≥ 95.0


Fresh Air Demand Control Using CO₂ Sensors

- ▶ ASHRAE 62.1 state need of Fresh air intake for indoor environment.
- ▶ However Hot Outdoor air will increase heat load of building.
- ▶ Therefore, use of CO₂ sensor to regulate the fresh air intake.

TABLE 7.5 | BUILDING PEAK COOLING LOAD REDUCTION DUE TO THE USE OF CO₂ DEMAND CONTROLLED FRESH AIR VENTILATION STRATEGY

Description	Peak cooling load (W/m ²)
No CO ₂ sensor	167.0
With CO ₂ sensor, Set point 900 ppm	164.7
Difference	2.3

FIGURE 7.16 | IMPACT ON BEI BASED ON CO₂ SET POINT IN A SPARSELY OCCUPIED BUILDING (40% DESIGN OCCUPANCY)



Chilled Water Plant

Equipment	Size	*COP @, 100% Load Conditions		*COP @ NPL V Conditions	
		Minimum COP	Maximum kWe/RT	Minimum COP	Maximum kWe/RT
Air cooled, with condenser	< 105 kW _r (30RT)	2.6	1.36	2.8	1.26
	≥ 105 kW _r and < 530 kW _r (150RT)	2.7	1.30	2.8	1.26
	≥ 530 kW _r and < 1060 kW _r (300RT)	2.8	1.26	2.9	1.21
	≥ 1060 kW _r (300RT)	2.9	1.21	3.0	1.18
Water cooled, positive displacement (Reciprocating and Scroll)	All capacities	3.9	0.90	4.0	0.88
Water cooled, positive Displacement (Rotary Screw)	< 530 kW _r (150RT)	4.0	0.88	4.2	0.84
	≥ 530 kW _r and < 1060 kW _r (300RT)	4.4	0.80	4.7	0.75
	≥ 1060 kW _r (300RT)	5.4	0.78	4.8	0.61
Water cooled, centrifugal	< 1060 kW _r (300RT)	5.4	0.68	4.7	0.75
	≥ 1060 kW _r (300RT)	5.7	0.62	5.2	0.68

What is COP stand for?

Coefficient of Performance (COP). A ratio of the cooling capacity in watts [kW] to the Total Power Input, in watts [kW] at any given set of Rating Conditions, expressed in kilowatts/kilowatt [kW/kW].

$$3.37 \text{ COP} = 1\text{kW}/(3.37\text{kW}/3.5172) = 1.044\text{kW/Ton}$$

Equipment	Size	*COP @, 100% Load Conditions		*COP @ NPL V Conditions	
		Minimum COP	Maximum kWe/RT	Minimum COP	Maximum kWe/RT
Air cooled, with condenser	< 105 kW _r (30RT)	2.6	1.36	2.8	1.26
	≥ 105 kW _r and < 530 kW _r (150RT)	2.7	1.30	2.8	1.26
	≥ 530 kW _r and < 1060 kW _r (300RT)	2.8	1.26	2.9	1.21
	≥ 1060 kW _r (300RT)	2.9	1.21	3.0	1.18
Water cooled, positive displacement (Reciprocating and Scroll)	All capacities	3.9	0.90	4.0	0.88
Water cooled, positive Displacement (Rotary Screw)	< 530 kW _r (150RT)	4.0	0.88	4.2	0.84
	≥ 530 kW _r and < 1060 kW _r (300RT)	4.4	0.80	4.7	0.75
	≥ 1060 kW _r (300RT)	5.4	0.65	5.8	0.61
Water cooled, centrifugal	< 1060 kW _r (300RT)	5.2	0.68	4.7	0.55
	≥ 1060 kW _r (300RT)	5.7	0.62	5.2	0.50

300RT & Above
0.617kW/Ton or better

Chilled Water and Condenser Pump Efficiency

Benchmark criteria: SS553

10.5.1.1 Hydronic Variable Flow Systems

The pump power limitation for chilled water systems shall be 349 kW/m³/s. The pump power limitation for condensing water systems is 301 kW/m³/s.

Cooling Tower Efficiency

ASHRAE 90.1

Table 3 – Performance requirements for heat rejection equipment

Equipment type ^{**}	Total system heat rejection capacity at rated conditions	Subcategory or rating condition	Performance required ^a	Test procedure
Propeller or axial fan cooling towers	All	35 °C Entering water 29 °C Leaving water 24 °C wb Outdoor air	≥ 3.23 L/s.kW	CTI ATC-105
Centrifugal fan cooling towers	All	35 °C Entering water 29 °C Leaving water 24 °C wb Outdoor air	≥ 1.7 L/s.kW	CTI ATC-105

^a For the purpose of this table,

- cooling tower performance is defined as the maximum flow rating of the tower divided by the nameplate rated motor power
- air-cooled condenser performance is defined as the heat rejected from the refrigerant divided by the nameplate rated motor power

For cooling tower flowrate = 3GPM per Ton
= 0.1893 litre per sec per ton

With every 3.23 L/s, we can remove 23 Ton

Therefore with every 1kW we remove 23Ton

Thus, minimum requirement = $(1/23) \times (1 + 1 / \text{Chiller COP})$

Plantroom Efficiency Baseline Reference

	Benchmark Reference	kW/Ton	COP
Chiller (Centrifugal > 300RT)	MS1525	0.617	
Chilled Water Pumps	SS553	0.0529	
Condenser Water Pumps	SS553	0.0457	
Cooling Towers	ASHRAE 90.1	0.055	
Total Plantroom System		0.77	4.7




Figure 5: Average annual chiller plant efficiency in kW/ton (COP). Input energy includes chillers, condenser pumps and tower fans, based on electrically driven centrifugal chiller plants in comfort conditioning applications with 42°F (5.6°C) nominal chilled water supply temperature and open cooling towers sized for 85°F (29.4°C) maximum entering condenser water temperature. Local climate adjustment for North America climates is ± 0.05 kW/ton.

VRF Minimum Efficiency by ASHRAE 90.1

**TABLE 6.8.1J Electrically Operated Variable Refrigerant Flow Air-to-Air and Applied Heat Pumps—
Minimum Efficiency Requirements (continued)**


Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure
VRF Ground source (cooling mode)	<40 kW	All	VRF Multisplit System 25°C entering water	3.93 COP _C	AHRI 1230
	<40 kW	All	VRF Multisplit System with Heat Recovery 25°C entering water	3.87 COP _C	
	≥40 kW	All	VRF Multisplit System 25°C entering water	3.22 COP _C	
	≥40 kW	All	VRF Multisplit System with Heat Recovery 25°C entering water	3.16 COP _C	

CHILLER:


- ✓ To configure Chiller Plant in a way that it operates at most efficient zone at most time;
- ✓ Design parameters should allow for low compressor head capability, increase evaporator mean saturated temp/pressure by variable flow thus improve chiller efficiency and prevent pipe freeze;
- ✓ Off-peak operating chiller should provide flexibility with load fluctuation and yet maintain good efficiency
- ✓ Chiller should also comes with good motor efficiency and power factor




Good Chiller Performance




Our simulations showed that Chiller Plant
could be downsized



Our simulations showed that Chiller Plant
could be downsized



Our simulations showed that Chiller Plant could be downsized




The Double-Penalty of Oversizing the Cooling Plant


High CAPEX
USD500,000

+

High OPEX
USD2,000,000 per year



ENERGY METERING PROPOSAL




Legend


 Compulsory Digital Power Meters

Actual Building vs design case study


Verification & Fine Tuning – Comparing Simulations against Actual Operations



Verification & Fine Tuning – Comparing Simulations against Actual Operations




Verification & Fine Tuning – Comparing Simulations against Actual Operations



Other Energy Efficient features: Regenerative Lift

Power (W) of 12 lifts over 7-day period for highrise office building in Kuala Lumpur

Analysis by IEN Consultants, March 2015



CONCLUDING REMARK

Buildings are Like a Leaky Bucket







with lots of unnecessary wastages

Plug the holes, and you are well on the way to a green inexpensive buildings
that people appreciate to use

Recommendation for Reading

ABOUT US FIVE COMPONENTS PUBLICATIONS NEWS & BLOGS RESOURCES EVENTS & CAMPAIGNS



Available at :
<http://bseep.gov.my/publications/>

Thanks You



By Tan Chin Hong
chinhong@ien.com.my
+60174145928